



NOTE:

1. DETAIL APPLIES TO WELDED DEFORMED WIRE REINFORCEMENT IN ACCORDANCE WITH ACI 318. MINIMUM WIRE SIZE = D4.0.
2. BI-DIRECTIONAL MATS SHOWN HERE, WITH REQUIRED REINFORCEMENT FOR EACH DIRECTION FURNISHED ON A COMMON MAT.
3. LAP SPLICE SHOWN IN ONE DIRECTION IS ALSO APPLICABLE FOR WIRES IN PERPENDICULAR DIRECTION. WWR MATS TO BE CONFIGURED BY WWR DETAILER TO SUIT PROJECT REQUIREMENTS.
4. OVERHANG-A = TYPICAL WIRE SPACING
5. OVERHANG-B = LAP SPLICE DIMENSION PER LAP SPLICE SCHEDULE

TYPICAL WDWR LAP SPLICE DETAIL - STRUCTURAL SLAB-ON-GROUND

NO SCALE D8

**WDWR LAP SPLICE
STRUCTURAL SLAB-ON-GROUND**

USE AND IMPLEMENTATION OF CONTENT SHOWN HERE SHALL BE AT THE DISCRETION OF A DULY LICENSED DESIGN PROFESSIONAL.

DRAWN BY: PA

DATE: 2021

SHEET NO.

WWR.4